

Specialty Machine Lago Vista, Texas

GOWNING ROOM and CLEANROOM IN "AT REST" CONDITIONS on the 19th day of September 2023

HAS BEEN TESTED TO MEET OR EXCEED THE PERFORMANCE PARAMETERS FOR A

ISO CLASS 5 CERTIFICATION @ 0.5 micron

IN ACCORDANCE WITH ISO 14644-1 & 2

and by the RECOMMENDATION of



this CERTIFICATION has been GRANTED.

IEST Supervisor