CERTIFICATE OF COMPLIANCE
CLEANROOM CERTIFICATION

Specialty Machine
Lago Vista, Texas

GOWNING ROOM and CLEANROOM IN "AT REST" CONDITIONS
on the 7th day of October 2026

HAS BEEN TESTED TO MEET OR EXCEED THE PERFORMANCE PARAMETERS FOR A

ISO CLASS 5 CERTIFICATION @ 0.5 micron

IN ACCORDANCE WITH ISO 14644-1 & 2
and by the RECOMMENDATION of

Sub-Micron
IEST MEMBER FOR CLEANROOM PERFORMANCE TESTING

this CERTIFICATION has been GRANTED.

IEST Supervisor _____